

# TÜV NEDERLAND B.V.

SOBA TEST INSTITUTE

Nusterweg 125

6136 KT SITTARD

## FIRE SAFE TEST CERTIFICATE

REGISTRATION / REPORT N°: 93.089.33

TÜV Nederland B.V./Division SOBA Test Institute

hereby grants : **RUDOLF VON SCHEVEN GmbH**  
Brinkerstrasse 1-7  
D - 45538 SPROCKHÖVEL

the right to publish this certificate verbatim and unabridged,  
considering the succesful testing by TÜV Nederland B.V. in compliance with the  
**British Standard 6755; Part 2; 1987; "fire type-testing requirements"**  
including amendments up till N°. 6712; 1991.

### TESTVALVE

**VALVE TYPE** : **Ball-Valve**, type KFK 06551-FS  
Floating-ball, Wrench-operated  
**Nominal Bore** : **DN 65**, Full-bore  
**Pressure Rating** : **ANSI Class 150**  
**Body material** : **GSC25**  
**Ball material** : **9S Mn 28**  
**Stem material** : **9S Mn 28**  
**Seat material** : **PTFE**  
**Body seal material** : **Graphite**  
**Stem seal material** : **Graphite**

**Drawing Number** : **KFK 06551-FS dd 10-05-1993**  
**Date of Testing** : **26-08-1993**  
**Report No.** : **B93.089.33**

### QUALIFICATION RANGE

This certificate represents the validity for valves qualified as:

**VALVE TYPE** : **Ball-Valve**, type KFK 06551-FS  
Floating ball, Soft-seated and Wrench-operated.  
**Qualified Sizes** : **Full-bore**  
DN 65, DN 80, DN 100 and DN 125  
(NPS 2½", NPS 3", NPS 4" and NPS 5")  
**Qualified Pressure Ratings** : **ANSI Class 150 and Class 300**  
(PN 16, PN 25 and PN 40)

Sittard, 30-09-1993  
TÜV Nederland B.V.  
SOBA Test Institute

  
Ing. J. Kesting, Managing Director